

L.A. COUNTY DPW

HAZARDOUS MATERIALS SYSTEM

REPORT: PWR050.002

DATE COMPILED: 01/06/04

TANKS INSPECTION JOB ORDER

INSP#: I000410982

RUN DATE: 04/15/04 16:38:39

CLOSURE BY REMOVAL

ASSC#: A000410838

PAGE: 1

FILE #: 011626-011678

NAME: SHULTZ STEEL COMPANY

ADD: 5321 E FIRESTONE BLVD

SOUTH GATE, CA 90280

AREA: 2J SMD: 95

XSTREET: RAYO AVE

THOMAS GUIDE: 0705-F4

CONTACT: NASH, PETER

TEL: 323 564 3281

AIN: 6

PROC: CLOSURE

SAMPLE REQUIRED? N

SAMPLE #: \_\_\_\_\_

INSP INFO: 04-16-04, @1:00, 1-10,000 GAL TANK, 3XS RINSE, HS MC CULLOUGH  
MC SQUARE 909-515-2190.PERM TYPE: T 0 TANK OPERATING PERMIT  
TTED

# OF TANKS: 1 STATUS: PERMI

	FREQUENCY	LAST PERFORMED	NEXT DUE
INSPECTION	12	01/07/04	04/24/05
SAMPLE			
SELF-MONITOR			

ASSGN TO: LENNOX FIELD OFFICE

SECT: FIELD INSPECTION UNIT

TANK #	OWNER TANK ID #	CAPACITY (GAL)	CONTENTS
003	3	10,000	DIESEL
CON: DOUBLE WALL			LDS: CONTINUOUS INTERSTITIAL MONITOR

RESULTS: INSPECTION NOT MADE. TANK HAS BEEN REMOVED  
SAMPLES HAVE BEEN TAKEN. CLOSURE PERMIT PREPARED  
AND TO BE SUBMITTED BY MC2 ENVIRONMENTAL.

REMARKS: SPOKE TO: TERESA M. LUGH

INSPECTOR: BRAD KUWANA INSPECTION DATE: 4/22/04DISP: CANC / BKE

COUNTY OF LOS ANGELES DEPARTMENT OF PUBLIC WORKS  
INDUSTRIAL WASTE/HAZARDOUS MATERIALS UNDERGROUND STORAGE  
CLOSURE INSPECTION REPORT

Date 4/22/04

Facility Name SHULTZ STEEL COMPANY File No. I- 11026-11678-

Site Address 5321 E. FIRESTONE BL. Permit No. 3248 T

Contact Person PETER NASH Phone (323) 564-3281

Type Inspection: ☒ Tank(s) & Piping ☐ Sump(s)  
☐ Tank(s) only ☐ Closure in place  
☐ Piping only ☐ Other \_\_\_\_\_

Contractor FRYS CONSTRUCTION Phone ( ) \_\_\_\_\_

Samples by \_\_\_\_\_ Phone ( ) \_\_\_\_\_

Geologist RAMON CHAVEZ, MC2 ENVIRONMENTAL Phone (909) 739-9593

Industrial Hygienist \_\_\_\_\_ Phone ( ) \_\_\_\_\_

Items closed:

Type ( <del>tank</del> /sump)	Contents	Capacity	Proper Sampling [yes] [no]	Perm Removal	Perm In-place
1. <u>DW TANK</u>	<u>DIESEL</u>	<u>10K</u>	<input type="checkbox"/> <input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
2. _____	_____	_____	<input type="checkbox"/> <input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
3. _____	_____	_____	<input type="checkbox"/> <input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4. _____	_____	_____	<input type="checkbox"/> <input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Observations: [yes] NA [no]

Visual contamination observed	<input type="checkbox"/>	<input type="checkbox"/>
Sampling of excavated soil required	<input type="checkbox"/>	<input type="checkbox"/>
Tanks structurally sound	<input type="checkbox"/>	<input type="checkbox"/>
Tanks remaining on site	<input type="checkbox"/>	<input type="checkbox"/>
Sampling conducted by DPW	<input type="checkbox"/>	<input type="checkbox"/>
Notice issued	<input type="checkbox"/>	<input type="checkbox"/>

How many \_\_\_\_\_ Monitor sys. \_\_\_\_\_  
Attach Chain-of-Custody \_\_\_\_\_  
Attach copy of Notice \_\_\_\_\_

Comments: \_\_\_\_\_

Include a detailed site survey on the reverse of this form.

Inspector BRAD KUWANA

Date 4/22/04

L.A. COUNTY DPW  
DATE COMPILED: 01/06/04  
RUN DATE: 03/31/04 18:13:22

HAZARDOUS MATERIALS SYSTEM  
TANKS INSPECTION JOB ORDER  
SCHEDULED INSPECTIONS

REPORT: PWB150.002  
INSP#: I000409598  
ASSC#: P00003248T  
PAGE: 1

FILE #: 011626-011678 NAME: SHULTZ STEEL COMPANY  
ADD: 5321 E FIRESTONE BLVD  
SOUTH GATE, CA 90280  
XSTREET: RAYO AVE  
CONTACT: NASH, PETER  
AREA: 2J SMD: 95  
THOMAS GUIDE: 0705-F4  
TEL: 323 564 3281  
AIN: 6

PROC: SAMPLE REQUIRED? N

INSP INFO: CERT #21614

PERM TYPE: T 0 TANK OPERATING PERMIT # OF TANKS: 1 STATUS: PERMITTED

	FREQUENCY	LAST PERFORMED	NEXT DUE
INSPECTION	12		04/24/04
SAMPLE			
SELF-MONITOR			

ASSGN TO: LENNOX FIELD OFFICE

SECT: FIELD INSPECTION UNIT

TANK #	OWNER TANK ID #	CAPACITY (GAL)	CONTENTS
003	3	10,000	DIESEL
CON: DOUBLE WALL		LDS: CONTINUOUS INTERSTITIAL MONITOR	

RESULTS: TANK REMOVED ON 4/16/04. SAMPLES TAKEN. CLOSURE  
REPORT TO BE SUBMITTED BY MCL ENVIRONMENTAL.

REMARKS: SEE TO TOPSIA M. L. L. L.

INSPECTOR: BRIAN KUWANA

INSPECTION DATE: 4/22/04

DISP:

CONF / BULK